

SHUT-DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS

I.R.O GSO CIRCLE MEPCO SAHIVAL FOR 05/2024

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Effected Area	Safety Supervisor
					From	To			
1	MEPCO	132KV Pakpatan/ 132/11KV, 20/26MVA P/TF T-4	06.05.24	Monday	8.00	13.00	To attend Oil leakage	No area will be effected the supply restored through 11KV Bus Coupler	Muhammad Akram FM Cell # 0302-7892530
2	MEPCO	132KV Noor Pur/ 132/11KV, 20/26MVA P/TF T-1	07.05.24	Tuesday	8.30	13.00	To connect 02-No 1000MCM Power Cables with Blue Phase to enhance the loading capacity	No area will be effected the supply restored through 11KV Bus Coupler	Muhammad Akram FM Cell # 0302-7892530
3	MEPCO	132KV Khanewal/ 132/11KV, 31.5/40MVA P/TF T-2	08.05.24	Wednesday	8.30	13.00	To connect 01-No 1000MCM Power Cables with each Yellow & Blue phases and 02-No 1000MCM with Red Phase to enhance the loading capacity	No area will be effected the supply restored through 11KV Bus Coupler	Muhammad Akram FM Cell # 0302-7892530
4	MEPCO	132KV Arifwala/ 132/11KV, 31.5/40MVA P/TF T-1	09.05.24	Thursday	7.00	9.00	Neutral earthing conductor require to be replaced due to excessive joints	No area will be effected the supply restored through 11KV Bus Coupler	Muhammad Akram FM Cell # 0302-7892530
5	MEPCO	132KV Arifwala/ 132/11KV, 31.5/40MVA P/TF T-3	09.05.24	Thursday	9.00	11.00	Neutral earthing conductor required to be replaced due to excessive joints	No area will be effected the supply restored through 11KV Bus Coupler	Muhammad Akram FM Cell # 0302-7892530
6	MEPCO	132KV Mianchannu / 132KV CB MCN-3 alongwith line Isolator 103	13.05.24	Monday	8.30	11.30	Annual maintenance / testing of 132KV CB MCN-3 & Line Isolator No. 103	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
7	MEPCO	132KV Mianchannu / 132KV CB MCN-4 alongwith line Isolator No. 104	13.05.24	Monday	11.30	14.30	Annual maintenance / testing of 132KV CB MCN-4 & Line Isolator No. 104	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
8	MEPCO	132KV Khanewal/ 132KV CB KNW-1 alongwith line Isolator No. 101	14.05.24	Tuesday	8.30	11.30	Annual maintenance / testing of 132KV CB KNW-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
9	MEPCO	132KV Khanewal/ 32KV CB KNW-4 alongwith line Isolator No. 104	14.05.24	Tuesday	11.30	14.30	Annual maintenance / testing of 132KV CB KNW-4 & Line Isolator No. 104	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
10	MEPCO	132KV Sheikh Fazal / 132KV CB SHF-1 alongwith line Isolator No. 101	15.05.24	Wednesday	8.30	11.30	Annual maintenance / testing of 132KV CB SHF-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
11	MEPCO	132KV Sheikh Fazal / 132KV CB SHF-2 alongwith line Isolator No. 102	15.05.24	Wednesday	11.30	14.30	Annual maintenance / testing of 132KV CB SHF-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
12	MEPCO	132KV Bunga Hayat/ 132KV CB BGH-1 alongwith line Isolator No 101	16.05.24	Thursday	8.30	11.30	Annual maintenance / testing of 132KV CB BGH-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
13	MEPCO	132KV Bunga Hayat/ 132KV Capacitor Bank, controlled by 132KV CB BGH-41	16.05.24	Thursday	8.30	14.30	Enhance the capacity of 132KV Capacitor Bank	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
14	MEPCO	132KV Arifwala/ 132KV Arifwala-Qabula T/L, controlled by 132KV CB ARW-2 - QBL-1	20.05.24	Monday	8.30	11.30	Annual maintenance / testing of 132KV CB ARW-2 & Line Isolator No.102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
15	MEPCO	132KV Pakpatan/ 132/11KV, 31.5/40MVA P/TF T-1	21.05.24	Tuesday	8.00	11.00	Power cable tightening and set right the power cable holding rack	No area will be effected the supply restored through 11KV Bus Coupler	Muhammad Akram FM Cell # 0302-7892530

P-01

Sr. No.	Disco	Name of Grid Station / Name of Equipment	Date	Day	Time		Purpose of Shut Down	Affected Area	Safety Supervisor
					From	To			
16	MEPCO	132KV Makhdoom Pur/ 132KV CB MPP-1 alongwith line Isolator No. 101	22.05.24	Wednesday	9.00	12.00	Annual maintenance / testing of 132KV CB MPP-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
17	MEPCO	132KV Makhdoom Pur / 132KV CB MPP-2 alongwith line Isolator No. 102	22.05.24	Wednesday	12.00	15.00	Annual maintenance / testing of 132KV CB MPP-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
18	MEPCO	132KV Khanewal/ 132KV CB KNW-3 alongwith line Isolator No. 103	28.05.24	Tuesday	8.30	11.30	Annual maintenance / testing of 132KV CB KNW-3 & Line Isolator No. 103	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
19	MEPCO	132KV Khanewal/ 132KV CB KNW-2 alongwith line Isolator No. 102	28.05.24	Tuesday	11.30	14.30	Annual maintenance / testing of 132KV CB KNW-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
20	MEPCO	132KV Kacha Khuh / 132KV CB KKH-1 & Line Isolator No. 101	29.05.24	Wednesday	8.30	11.30	Annual maintenance / testing of 132KV CB KKH-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
21	MEPCO	132KV Kacha Khuh / 132KV CB KKH-2 & Line Isolator No. 102	29.05.24	Wednesday	11.30	14.30	Annual maintenance / testing of 132KV CB KKH-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
22	MEPCO	132KV Kassowal New/ 132KV CB KSW-1 alongwith line Isolator No. 101	30.05.24	Thursday	8.30	11.30	Annual maintenance / testing of 132KV CB KSW-1 & Line Isolator No. 101	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530
23	MEPCO	132KV Kassowal New/ 132KV CB KSW-2 alongwith line Isolator No. 102	30.05.24	Thursday	11.30	14.30	Annual maintenance / testing of 132KV CB KSW-2 & Line Isolator No. 102	No area will be effected due to dual source	Muhammad Akram FM Cell # 0302-7892530

Pod