

SHUT DOWNS ON 132KV TRANSMISSION LINES / GRID STATIONS

I.R.O GSO CIRCLE MEPCO SAHIWAL FOR 01/2024

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Effected Area | Remarks | Safety Supervisor |
|---------|-------|--|----------|-----------|------|-------|---|---|---------|--|
| | | | | | From | To | | | | |
| 1 | MEPCO | 132KV Mianchannu /132/11KV, 31.5/40MVA P/TF T-3 | 02.01.24 | Tuesday | 9.00 | 15.00 | Annual maintenance / testing | 11KV O/G J.T.M, Q.T.M, M.T.M, New Kassowal, City-4, L.B.H.S. S.P.Mills, Bodhla, A.U.P.M, City-2, Industrial Estate, City-3, Chak 8-BR, Chak 13 (14-No feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 2 | MEPCO | 132KV Vehari/ 132/11KV 20/26MVA P/TF T-3 | 02.01.24 | Tuesday | 8:00 | 14:00 | Annual Maintenance/testing | 11 KV O/G Chak 22/WB, Creacent Factory, Chak 182/E.B, Defence View, SS Feeds, City-III, Defence View VIP Block, Madina Colony feeders | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 3 | MEPCO | 132KV Kachakhu/ 132/11KV, 20/26MVA P/TF T-2 | 03.01.24 | Wednesday | 9.00 | 15.00 | Annual maintenance / testing | 11KV O/G Vehari Road, Chak 28/10-R, Chak 54/15-L, Kachakhu City, Chab Banglow (05-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 4 | MEPCO | 66KV Chishtian/66KV bus bar controlled by 66KV CB CHN-1 | 03.01.24 | Wednesday | 9:00 | 15:00 | Annual Maintenance of 66KV bus bar, 2.5MVA, 66/11KV P/TF T-2 and 66KV C.B CHN-1 | Whole area of 66KV Grid Station Chishtian (11 KV O/G Madrassa, Main Bazar, Park, Gulshan feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 5 | MEPCO | 66KV Hasil Pur-Chishtian T/L controlled by 66KV CB HSP-5 - CHN-1 | 03.01.24 | Wednesday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 66KV Grid Station Bukhshan Khan and Chishtian (11 KV O/G Madrassa, Main Bazar, Park, Gulshan, City-I Bukhshan Khan, Syadan Wala & City-II Bukhshan Khan feeders) | | Fazal Ur Reham (AET Hasil Pur) 0301-8725937 |
| 6 | MEPCO | 132KV Sahiwal New / 132/11KV, 20/26MVA P/TF T-2 | 04.01.24 | Thursday | 9.00 | 15.00 | Annual maintenance / testing | 11KV O/G Ansar, Chak 85, Tariq Bin Zaid, Shadman, (04-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 7 | MEPCO | 132KV Hasil Pur/ 132/11KV 31.5/40MVA P/TF T-3 | 04.01.24 | Thursday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G Sheikh Wahin, Al Tahir, City-I, Tubwell, M/Pnah, AL-Haider, Settilte Town, City-II Hasil Pur, Water Works, Anaytee, Shah Pur feeders | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 8 | MEPCO | 132KV Haroon Abad-Donga Bonga T/L controlled by 132KV CB HRB-5 - DBA-1 | 04.01.24 | Thursday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Donga Bonga. (11 KV O/G City Donga Bonga, Rasool Pura feeders) | | Behzad Ali (AET Bahawal Nagar) 0302-8290668 |
| 9 | MEPCO | 132KV Burewala /132/11KV, 31.5/40MVA P/TF T-2 | 08.01.24 | Monday | 9.00 | 15.00 | Annual maintenance / protection testing | 11KV O/G Lahore Road, BTM-3, Tufail Shaheed, City-1, Shah Faisal, Royal Garden, Dallon Banglow, Kamand, (08-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 10 | MEPCO | 132KV Faqir Wali-Khichi Wala T/L controlled by 132KV CB FQW-2 - KHW-1 | 08.01.24 | Monday | 9:00 | 13:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Khichi Wala, Fort Abbas and Marrot. (11 KV O/G City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Gafoor Shaheed, City Khichi Wala, 75 Adda, Fazal Shah, Latif Abad, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders) | | Behzad Ali (AET Bahawal Nagar) 0302-8290668 |
| 11 | MEPCO | 132KV Khichi Wala/ 132/11KV 10/13MVA P/TF T-2 | 08.01.24 | Monday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G 75 Adda, Fazal Shah, Latif Abad feeders | | Abdul Rehman (AEM Vehari) 0302-8290659 |

P=01

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Effected Area | Remarks | Safety Supervisor |
|---------|-------|--|----------|-----------|------|-------|---|---|---------|--|
| | | | | | From | To | | | | |
| 12 | MEPCO | 132KV Khichi Wala/ 132KV bus bar controlled by 132KV CB KHW-1 - KHW-2 | 08.01.24 | Monday | 9:00 | 13:00 | Annual maintenance of 132KV bus bar at 132KV G/S Khichi Wala and Annual maintenance of 132KV C.Bs KHW-1 & KHW-2 | Whole area of 132KV G/S Khichi Wala, Fort Abbas and Marrot. (11 KV O/G City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Gafoor Shaheed, City Khichi Wala, 75 Adda, Fazal Shah, Latif Abad, Marrot-1, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 13 | MEPCO | 132KV Pakpattan/ Pakpattan-Noor pur T/L controlled by 132KV CB PPT-1-NPR-3 | 09.01.24 | Tuesday | 9.00 | 12.00 | Annual maintenance / testing of 132KV CB PPT-1 & Line Isolator No. 101 | 11KV O/G Power House, Chak Shafi, Sanday Kha, Malka Hance, Khawaja Aziz Makki, Husain Abad, Chan Peer, Al-Fareed, New Malka Hance, Bonga Hayat, Fareed Nager, Ghulam Hayder, Sarwar Shaheed, Mehmoob Shah, Jail, D.H.Q, Mubasher Shaheed, Dost Muhammad, Moj Darya, Masoom Shah, City, Satluj, Miran Shah, Gunj Shakar, Iqbal Shaheed, Abdul Kareem, Mushtaq Shaheed, Ali Mahi. (28-No feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 14 | MEPCO | 132KV Pakpattan/ 132 Bus Bar controlled by 132KV CB PPT-1-NPR-3 along with line Isolator 101 | 09.01.24 | Tuesday | 9.00 | 15.00 | Annual maintenance of 132KV Bus Bar, line isolator No. 101 11KV Bus Coupler, and tightening of all power cables as well as Jumpers & droppers | Muhammad Akram Foreman Cell # 0302-7892530 Akbar Iqbal Zahid Cell # 0301-2789014 | | |
| 15 | MEPCO | 132KV Noor/ 132KV Bus Bar controlled by 132KV CB NPR-1, NPR-2, NPR-3 alongwith line isolator 101, 102, 103 | 09.01.24 | Tuesday | 9.00 | 15.00 | Annual maintenance of 132KV Bus Bar, line isolator No. 101, 102 & 103, 11KV Bus Coupler, and tightening of all power cables as well as Jumpers & droppers | 11KV O/G Waris Shah, Bayas, Noor Jang, Ittfaq, Sher Shah, Noor Pur, Hari Pur, Chak Ghuri, Fouji Fresh & Freez, Jahan Khan & Jaffar Shah (11-No Feeders Noor Pur) and 11KV O/G Power House, Chak Shafi, Sanday Kha, Malka Hance, Khawaja Aziz Makki, Husain Abad, Chan Peer, Al-Fareed, New Malka Hance, Bonga Hayat, Fareed Nager, Ghulam Hayder, Sarwar Shaheed, Mehmoob Shah, Jail, D.H.Q, Mubasher Shaheed, Dost Muhammad, Moj Darya, Masoom Shah, City, Satluj, Miran Shah, Gunj Shakar, Iqbal Shaheed, Abdul Kareem, Mushtaq Shaheed, Ali Mahi. (28-No feeders Papattan) | | Altaf Hussain, LS-I Cell # 0302-8291775 Saeed Ashraf AFM 0300-9691037 |
| 16 | | 132KV Noor Pur -Pakpattan T/L controlled by 132KV CB NPR-3-PPT-1 | 09.01.24 | Tuesday | 9.00 | 15.00 | Washing / cleaning of disc insulators | 11KV O/G Waris Shah, Bayas, Noor Jang, Ittfaq, Sher Shah, Noor Pur, Hari Pur, Chak Ghuri, Fouji Fresh & Freez, Jahan Khan & Jaffar Shah (11-No Feeders Noor Pur) and 11KV O/G Power House, Chak Shafi, Sanday Kha, Malka Hance, Khawaja Aziz Makki, Husain Abad, Chan Peer, Al-Fareed, New Malka Hance, Bonga Hayat, Fareed Nager, Ghulam Hayder, Sarwar Shaheed, Mehmoob Shah, Jail, D.H.Q, Mubasher Shaheed, Dost Muhammad, Moj Darya, Masoom Shah, City, Satluj, Miran Shah, Gunj Shakar, Iqbal Shaheed, Abdul Kareem, Mushtaq Shaheed, Ali Mahi. (28-No feeders Papattan) | | Muhammad Nafees LS Cell # 0302-8291776 |
| 17 | MEPCO | 132KV Kehror Pacca/132/11KV 31.5/40MVA P/TF T-2 | 09.01.24 | Tuesday | 9:00 | 15:00 | Annual Maintenance/testing | (11 KV O/G Factory, Goth Bahar, City Kehror Pacca, Fateh Shah, Main Bazar, Mustafa Shaheed, Shah Muhammad feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 18 | MEPCO | 132KV Kehror Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 & 101 | 09.01.24 | Tuesday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Dunya Pur (11 KV O/G Ali Sher, Thatha Road, Sadat, Khushi Muhammad, City Noor Peer, Ghulam Rasool, Jallah, City Dunya Pur, Qutab Pur, Nasrullah Tarin, Model Town & Sadiq Shaheed feeders) | | Obaid Ullah (AET Vehari) 0302-8290667 |
| 19 | MEPCO | 132KV Noor Pur / 132/11KV, 20/26MVA P/TF T-2 | 10.01.24 | Wednesday | 9.00 | 15.00 | Annual maintenance / protection testing | 11KV O/G Sher Shah, Noor Pur, Hari Pur, Chak Ghuri, Fouji Fresh & Freez, (05-No Feeders) | P=02 | Muhammad Akram Foreman Cell # 0302-7892530 |

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Effectuated Area | Remarks | Safety Supervisor |
|---------|-------|--|----------|-----------|-------|-------|---|---|---------|--|
| | | | | | From | To | | | | |
| 20 | MEPCO | 132KV Chishtian/132/11KV 20/26MVA P/TF T-3 | 10.01.24 | Wednesday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G Settelite Town, Shouq Elahi, Sher Fareed, Gajiani feeders | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 21 | MEPCO | 132KV Sahiwal New /132/11KV, 31.5/40MVA P/TF T-1 | 11.01.24 | Thursday | 8.30 | 14.30 | Annual maintenance / protection testing | 11KV O/G Civil Hospital, T.V Corporation, College Road, Kourey Shah, Noor Shah, Asiyana Housing Scheme, DHQ Teaching Hospital, Ratti Tibbi, (08-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 22 | MEPCO | 132KV Mailsi/132/11KV 20/26MVA P/TF T-3 | 11.01.24 | Thursday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G City-II, Irshad Ahmad Khan, Niaz Pur, Sargana feeders | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 23 | MEPCO | 132KV Hasil Pur-Chuna Wala T/L controlled by 132KV CB HSP-7 - CNW-1 | 11.01.24 | Thursday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Chuna Wala (Whole area of 11KV O/G City Chuna Wala, New Cholistan and Al-Fateh feeders) | | Fazal Ur Reham (AET Hasil Pur) 0301-8725937 |
| 24 | MEPCO | 132KV Burewala Old/ 132KV Burewala Old-Burewala T/L, controlled by 132KV CB BWO-1-BRW-3 | 15.01.24 | Monday | 9.00 | 12.00 | Annual maintenance / testing of 132KV CB BWO-1 | 11KV O/G Ghous Pak, Shafiq Shaheed, Madina Colony, B&R, Fetah Shah, Dewan Sahib, Habib Colony, & Khair Wala Feeders (08-No feeders Burewala Old) 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders Sahuka) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 25 | MEPCO | 132KV Burewala Old/ 132KV Burewala Old-Sahuka T/L, controlled by 132KV CB BWO-2 - SKA-1 | 15.01.24 | Monday | 12.00 | 15.00 | Annual maintenance / testing of 132KV CB BWO-2 | 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 26 | MEPCO | 132KV Burewala Old/ 132KV Bus Bar controlled by 132KV CB BWO-1-BWO-2 alongwith line isolator 101 & 102 | 15.01.24 | Monday | 9.00 | 15.00 | Annual maintenance of 132KV Bus Bar and line isolator No. 101, 102 11KV Bus Coupler, and tightening of all power cables as well as Jumpers & droppers | 11KV O/G Ghous Pak, Shafiq Shaheed, Madina Colony, B&R, Fetah Shah, Dewan Sahib, Habib Colony, & Khair Wala Feeders (08-No feeders Burewala Old) 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders Sahuka) | | Muhammad Akram Foreman Cell # 0302-7892530 Muhammad Nafees LS Cell # 0302-8291776 |
| 27 | MEPCO | 132KV Burewala Old - Sahuka T/L, controlled by 132KV CB BWO-2 - SKA-1 | 15.01.24 | Monday | 9.00 | 15.00 | Washing / cleaning of disc insulators | 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders) | | Altuf Hussain, LS-I Cell # 0302-8291775 |
| 28 | MEPCO | 132KV Donga Bonga/ 132KV bus bar controlled by 132KV CB DBA-1 | 15.01.24 | Monday | 9:00 | 12:00 | Annual Maintenance of 132KV bus bar, 132KV C.B C:BA-1 and isolator 101 | Whole area of 132KV G/S Donga Bonga (11 KV O/G City Donga Bonga, Rasool Pura feeders) | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 29 | MEPCO | 132KV Donga Bonga/ 132/11KV 10/13MVA P/TF T-1 | 15.01.24 | Monday | 9:00 | 15:00 | Annual Maintenance/testing | 11KV O/G City Donga Bonga, Rasool Pura feeders) | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 30 | MEPCO | 132KV Kameer / 132/11KV, 20/26MVA P/TF T-2 | 16.01.24 | Tuesday | 9.00 | 15.00 | Annual maintenance / protection testing | 11KV O/G Baba Qutab Shah, Karman Wala, Al-Noor, Chak 19 Moor. (04-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 31 | MEPCO | 132KV Karam Pur/ 132/11KV 20/26MVA P/TF T-2 | 16.01.24 | Tuesday | 8:30 | 14:30 | Annual Maintenance/testing | (11 KV O/G Karam Pur, Tabark Wah, Idrees Shaheed feeders) | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 32 | MEPCO | 132KV Sheikh Fazal / 132/11KV, 20/26MVA P/TF T-1 | 17.01.24 | Wednesday | 9.00 | 15.00 | Annual maintenance / protection testing | 1KV O/G Ghazi, Sheikh Fazal, Saleem Shaheed, Arif Shah (04-No feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 33 | MEPCO | 132KV Kehror Pacca/132/11KV 31.5/40MVA P/TF T-3 | 17.01.24 | Wednesday | 9:00 | 15:00 | Annual Maintenance/testing | (11 KV O/G Shah Pur, Sohail Pur, Ali Pur, Mehar Shah, Anayat ALI, Mangwani, Qadir Pur Cheema feeders) | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 34 | MEPCO | 132KV Minchin Abad-Mecleod Gunj T/L controlled by 132KV CB MNA-2 - MLG-1 | 17.01.24 | Wednesday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Mecleod Gunj (11 KV O/G M/Gunj, M.Abad-II, Anwar Shaheed & Al-Mushtaq, City, Amruka, M/Abad/1 & Head Sulemanki feeders) | | Behzad Ali (AET Bahawal Nagar) 0302-8290668 |

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Effectuated Area | Remarks | Safety Supervisor |
|---------|-------|---|----------|-----------|------|-------|---|--|---------|--|
| | | | | | From | To | | | | |
| 35 | MEPCO | 132KV Qabula / 132KV Bus Bar controlled by 132KV CB QBL-1 - QBL-2 alongwith line Isolator 101 & 102 | 18.01.24 | Thursday | 9.00 | 15.00 | Annual maintenance of 132KV Bus Bar and line isolator No. 101, 102 11KV Bus Coupler, and tightening of all power cables as well as Jumpers & droppers | 11KV O/G Mouj Darya, Muhammad Nagar, Peer Fazal, Shehar Jillani, Aslam Shaheed, Mehdi Khan, Ahmad Yar, Lal Shah, Gamman Shah, Raja Fida Hussain, Chak 117/EB, Ch: Naseem, Mashooq Ali Shaheed (12-No Feeders effected) | | Muhammad Akram Foreman Cell # 0302-7892530 Muhammad Nafees LS Cell # 0302-8291776 |
| 36 | MEPCO | 66KV Chishtian/66/11KV 10/13MVA P/TF T-1 | 18.01.24 | Thursday | 9:00 | 15:00 | Annual Maintenance/testing | 11KV O/G Main Bazar, Park, Gulshan feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 37 | MEPCO | 132KV Chishtian 220KV-Dahran Wala T/L controlled by 132KV CB E8Q1 - DNW-1 | 18.01.24 | Thursday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Dahran Wala (11 KV O/G City Chuna Wala, Bukhshan Khan, Al Gazi, Al Fateh, AL Murad, Shaheed Chowk and City Dahran Wala feeders) | | Fazal Ur Reham (AET Hasil Pur) 0301-8725937 |
| 38 | MEPCO | 132KV Dahran Wala/ 132KV bus bar controlled by 132KV CB DNW-1 | 18.01.24 | Thursday | 9:00 | 15:00 | Annual maintenance of 132KV bus bar at 132KV G/S Dahran Wala and Annual maintenance of 132KV C.B DNW-1 | Whole area of 132KV G/S Dahran Wala (11 KV O/G City Chuna Wala, Bukhshan Khan, Al Gazi, Al Fateh, AL Murad, Shaheed Chowk and City Dahran Wala feeders) | | Fazal Ur Reham (AET Hasil Pur) 0301-8725937 |
| 39 | MEPCO | 132KV Harappa / 132/11KV, 20/26MVA P/TF T-2 | 22.01.24 | Monday | 9.00 | 15.00 | Annual maintenance / protection testing | 11KV O/G Sahiwal Road, Harappa Textile Mill, Shah Murad, S.S.T Mill, Ganji Bar, Suraj Fertilizer, Sadiq Feed Mills (07-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 40 | MEPCO | 132KV Noor Ser/ 132/11KV 20/26MVA P/TF T-1 | 22.01.24 | Monday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G Faqir Shah, Muqem Shah, Abdullah, Mohar Wali feedes | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 41 | MEPCO | 132KV Sahiwal-III /132KV Bus Bar controlled by 132KV CB SHT-1 - SNT-2 aongwith line Isolator 101 & 102 | 23.01.24 | Tuesday | 8.30 | 14.30 | Annual maintenance of 132KV Bus Bar and line isolator No. 101 & 102 11KV Bus Coupler, and tightening of all power cables as well as Jumpers & droppers | 11KV O/G Shah Madar, Murshad Abad, High Security Prison, Scheme No.3, Medical College, Fareed Town, Ali Garh, Haji Abdul Quyyum Hospital, Jehaz Ground, Police Line, Abdullah Shah, Central Jail, Rafi Garden, Booti Pall, Qutab Shahana (15-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 42 | MEPCO | 132KV Chak 211/W.B/ 132/11KV 20/26MVA P/TF T-3 | 23.01.24 | Tuesday | 9:00 | 15:00 | Annual Maintenance/testing | (11 KV O/G Zia Khan, Dokota, Chak No. 227/W.B, Fida Hussain Shaheed feeders) | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 43 | MEPCO | 132KV Ludden-Karam Pur T/L controlled by 132KV CBs LDN-2 - KPU-1 | 23.01.24 | Monday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Karam Pur (11KV Aftab Mehmood, Tipu, Muhammad Shah, Hassan Shah, Zia Shaheed, Karam Pur, Tabark Wah & Idrees Shaheed feeders) | | Fazal Ur Reham (AET Hasil Pur) 0301-8725937 |
| 44 | MEPCO | 132KV Burewala/ 132KV Bus Bar controlld by 132KV CB BRW-1, 02, 03, 04, 05 & 06 alongwith Line Isolators 101, 102, 103, 104, 105 & 106 | 24.01.24 | Wednesday | 9.00 | 15.00 | Annual maintenance of 132KV Bus Bar, line isolator No. 101, 102, 103, 104, 105 & 106 11KV Bus Coupler, and tightening of all power cables as Jumpers & droppers | 11KV O/G Shabbir Shaheed, Hameed Shaheed, Tufail Shaheed, City-2, Machi Wal, City-6, Mana More, Lahore Road, City-5, City-3, Shah Faisal, BTM-3, Kamand, Dallon Banglow, Royal Garden, Masoom Shah, City-4, Zaheer Nager, Gaggo, Ghala Mandi, City-1, Mujahid Colony & Sabir Raza Shaheed. (23-No Feeders) 11KV O/G Ghous Pak, Shafiq Shaheed, Madina Colony, B&R, Fetah Shah, Dewan Sahib, Habib Colony, & Khair Wala Feeders (08-No feeders Burewala Old) 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders Sahuka) | | Muhammad Akram Foreman Cell # 0302-7892530 Muhammad Nafees LS Cell # 0302-8291776 |

P=04

| Sr. No. | Disco | Name of Grid, Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Effectuated Area | Remarks | Safety Supervisor |
|---------|-------|--|----------|-----------|------|-------|--|---|---------|--|
| | | | | | From | To | | | | |
| 45 | | 132KV Burewala/ 132KV T/L Burewala- Burewala Old, controlled by 132KV CB BRW-3 - BWO-1 | 24.01.24 | Wednesday | 9.00 | 12.00 | Annual Maintenance of 132KV CB BRW-3 | 11KV O/G Ghaus Pak, Shafiq Shaheed, Madina Colony, B&R, Fetah Shah, Dewan Sahib, Habib Colony, & Khair Wala Feeders(08-No feeders Burewala Old) 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders Sahuka) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 46 | | 132KV T/L Burewala Old - Burewala, controlled by 132KV CB BWO-1 & BRW-3 | 24.01.24 | Wednesday | 9.00 | 15.00 | Washing / cleaning of disc insulators | 11KV O/G Ghaus Pak, Shafiq Shaheed, Madina Colony, B&R, Fetah Shah, Dewan Sahib, Habib Colony, & Khair Wala Feeders(08-No feeders Burewala Old) 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali, Jamlarya, Sahuka, Saldara, Sarwar Shah, Haji Sher, Jodhaka, Subhan Shah & Yousaf Shaheed (12-No feeders Sahuka) | | Altaf Hussain, LS-I Cell # 0302-8291775 |
| 47 | MEPCO | 132KV Minchin Abad/ 132KV bus bar controlled by 132KV CB MNA-1 & MNA-2 | 24.01.24 | Wednesday | 9:00 | 15:00 | 01. Annual maintenance of 132KV bus bar at 132KV G/S Minchin Abad and Annual maintenance of 132KV C.Bs MNA-1, MNA-2 02. Annual maintenance of 132KV bus bar at 132KV G/S Mecleod Gunj and Annual maintenance of 132KV C.B MLG-1 | Whole area of 132KV G/S Minchin Abad & Mecleod Gunj (11 KV O/G Fidai Shah, City Minchin Abad, Railway Road, Farooq Shaheed, Mehmood, PPN Road M/Gunj, M.S.G Road, M.Abad-II, Anwar Shaheed, Al-Mushtaq, City, Amruka, M/Abad/1 & Head Sulemanki feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 48 | MEPCO | 132KV Bahawal Nagar II-Minchin Abad T/L controlled by 132KV CB BNR-2 - MNA-1 | 24.01.24 | Wednesday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Minchin Abad & Mecleod Gunj (11 KV O/G Fidai Shah, City Minchin Abad, Railway Road, Farooq Shaheed, Mehmood, PPN Road M/Gunj, M.S.G Road, M.Abad-II, Anwar Shaheed, Al-Mushtaq, City, Amruka, M/Abad/1 & Head Sulemanki feeders) | | Behzad Ali (AET Bahawal Nagar) 0302-8290668 |
| 49 | MEPCO | 132KV Hoota /132/11KV, 20/26MVA P/TF T-2 | 25.01.24 | Thursday | 9.00 | 15.00 | Annual maintenance / protection testing | 11KV O/G Irshad Distgheer, Zafar shaheed & Baba Fareed(03-No feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 50 | MEPCO | 132KV Dunya Pur/ 132/11KV 20/26MVA P/TF T-2 | 25.01.24 | Thursday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G Jallah, City Dunya pur, Qutab Pur, Sadat, Model Town feeders | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 51 | MEPCO | 132KV Sahuka / 132/11KV, 20/26MVA P/TF T-1 | 29.01.24 | Monday | 9.30 | 15.30 | Annual maintenance / protection testing | 11KV O/G Sadat, Umar Pur, Al-Abas, Murad Ali (04-No feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 52 | MEPCO | 132KV Noor Ser/ 132/11KV 10/13MVA P/TF T-2 | 29.01.24 | Monday | 9:00 | 15:00 | Annual Maintenance/testing | 11KV O/G Takhat Mehal, Jand Wala feeders | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 53 | MEPCO | 132KV Haroon Abad-Faqir Wali T/L controlled by 132KV CB HRB-3 - FQW-1 | 29.01.24 | Monday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Faqir Wali, Khichi Wala, Fort Abbas and Marrot. (11 KV O/G City Faqir Wali, Wains, Canal 7R, City-II Faqir Wali, Yateem Wala, Rural, Mehria City, City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Gafoor Shaheed, City Khichi Wala, 75 Adda, Fazal Shah, Latif Abad, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders) | | Behzad Ali (AET Bahawal Nagar) 0302-8290668 |

205

| Sr. No. | Disco | Name of Grid Station / Name of Equipment | Date | Day | Time | | Purpose of Shut Down | Effected Area | Remarks | Safety Supervisor |
|---------|-------|--|----------|-----------|------|-------|--|---|---------|--|
| | | | | | From | To | | | | |
| 54 | MEPCO | 132KV Fort Abbas/ 132KV bus bar controlled by 132KV CB FTA-1 - FTA-2 | 29.01.24 | Monday | 9:00 | 15:00 | Annual maintenance of 132KV bus bar at 132KV G/S Fort Abbas and Annual maintenance of 132KV C.Bs FTA-1 & FTA-2 | Whole area of 132KV G/S Fort Abbas and Marrot. (11 KV O/G City Fort Abbas, Fort, Quraish, Rafiq Shaheed, Khichi Wala, Walhar, Rafique Abad, THQ Hospital Fort Abbas, Marrot-I, City Marrot, Mansoor, Cholistan, Zia, Rohi, Sardar, Chappu & Meer Garh feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 55 | MEPCO | 132KV Qadir Abad/ 132KV Bus Bar controlling 132KV CB QDR-1, 2, 3, 4, 5, 6 alongwith line Isolators | 30.01.24 | Tuesday | 9.00 | 15.00 | Annual maintenance of 132KV Bus Bar, line isolator No. 101, 102, 103, 104, 105 & 106 11KV Bus Coupler, and tightening of all power cables .as well as Jumpers & droppers | 11KV O/G Hafiz Daim, Khan Kamal, Asia Poultry Feeds, Qadir Abad, Chak 46/5-L, Chak 73/4-R, Nargis Textile Mills(MEPCO) & Lekson Tobacco Co. Gamber (LESCO) feeders & 132KV G/S whole ares of Sadar Gogera (LESCO) (09-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 Muhammad Nafees LS |
| 56 | MEPCO | 132KV Hasil Pur/ 132/11KV 10/13 MVA P/TF T-4 | 30.01.24 | Tuesday | 9:00 | 15:00 | Annual Maintenance/testing | 11KV O/G Islam Pura, Sarwar Kot and Qalandar Pur feeders) | | Abdul Rehman (AEM Vehari) 0302-8290659 |
| 57 | MEPCO | 132KV Bonga Hayat / 132/11KV, 31.5/40MVA P/TF T-2 | 31.01.24 | Wednesday | 9.00 | 15.00 | Annual maintenance / protection testing | 11KV O/G Chak Badi, Qudrat Ullah, Sikandar Chowk, Zubair Feed, Farid Kot, Al-Wardi, Wandela Jangeer (07-No Feeders) | | Muhammad Akram Foreman Cell # 0302-7892530 |
| 58 | MEPCO | 132KV Bahawal Nagar-II/ 132/11KV 10/13MVA P/TF T-2 | 31.01.24 | Wednesday | 9:00 | 15:00 | Annual Maintenance/testing | 11 KV O/G Bala Arain, Jhanjran Wali, Chishtian Road feeders | | Abdul Rahman (AEM Vehari) 0335-0267728 |
| 59 | MEPCO | 132KV Kehrur Pacca-Dunya Pur T/L controlled by 132KV CB KRP-1 & 101 | 31.01.24 | Wednesday | 9:00 | 15:00 | Washing/cleaning of disc insulators | Whole area of 132KV G/S Dunya Pur (11 KV O/G Ali Sher, Thatha Road, Sadat, Khushi Muhammad, City Noor Peer, Ghulam Rasool, Jallah, City Dunya Pur, Qutab Pur, Nasrullah Tarin, Model Town & Sadiq Shaheed feeders) | | Obaid Ullah (AET Vehari) 0302-8290667 |

P=06